

MONTHLY REPORT OF THE NATIONAL OCCUPATIONAL SAFETY AND HEALTH
DEPARTMENT FOR MAY 2026

1.	Enforcement Section (North) and Public Service Unit	Number
	Visits	41
	Complaint investigations	5
	Enquiries	-
	Total	46
2.	Enforcement Section (South) and Maritime Safety Unit	
	Visits	19
	Complaint investigations	11
	Enquiries	-
	Total	30
3.	Employees' Lodging Accommodation Section	
	Visits	104
	Complaint investigations	9
	Enquiries	3
	Total	116
4.	Construction Section	
	Visits	73
	Complaint investigations	1
	Enquiries	35
	Total	109

5.	Accident and Prosecution Section			
(a)	Accident Unit			
	Notifiable fatal accidents	3		
	Notifiable non-fatal accidents	43		
	Non-notifiable accidents	10		
	Total	56		
	Dangerous occurrences	-		
	Occupational diseases	-		
	Field visits in relation to accident	42		
(b)	Prosecution Unit		Number	
			Cases	Counts
	Cases lodged in Court		9	17
	Cases taken proforma		25	34
	Cases taken for trial/hearing		8	10
	Cases in which judgement delivered (details at annex)		12	21
	Total No. of Cases		54	82
	Cases - Information drafted		9	17
	Case files prepared for trial/hearing		34	63
	Total No. of Cases		43	80
6.	Occupational Safety and Health Training and Information Centre (OSHTIC)			
	Training sessions	Number	Number of participants	
			M	F
	At the OSHTIC	-	-	-
	On site	-	-	-
	Training of Ministry's staff	-	-	-
	Total	-	-	-

7.	Registry Section	Number
	Applications for renewal of certificate of registration of factory received	34
	New applications for registration of factory received	9
	No. of closed files	-
	Steam boilers registered	2
	New application for Lodging Accommodation Permit received	67
	Application for renewal of Lodging Accommodation Permit received	43
	Number of Lodging Accommodation Permit files closed	-
	As at May 2026	
	Active factory files	4,002
	Lodging Accommodations with valid Lodging Accommodation Permit	3,261
	General Places of Work files (GPW)	2,060
	Buildings files (BDG)	500
	Republic of Mauritius files (RM)	391
	Agriculture files (AGR)	60
	Construction files (CONST)	1,215
	Registered Safety and Health Officers	585
	Scaffold Contractors with valid Scaffold Contractor's Permit	70

Cases in which judgement delivered

- 1st Case: St Malo Exports Ltd**
- Date case filed: 30 April 2024
- Count I: Failing to ensure the safety, health and welfare at work of its employees. Case dismissed.
- 2nd Case: Balraj Sooklall**
- Date case filed: 24 February 2026
- Count I: Failing to ensure the safety, health and welfare at work of its employees. Was sentenced to a fine of Rs20,000/- and cost of Rs200/-.
- 3rd Case: Sinohydro Corporation (Mauritius) Limitee**
- Date case filed: 16 March 2026
- Count I: Causing a scaffold, except an excluded scaffold, to be constructed, erected, installed, re-positioned, altered, maintained, repaired or dismantled without holding a Scaffold Contractor's Permit or enlisting the services of a scaffold contractor. Was sentenced to a fine of Rs5,000/- and cost of Rs200/-.
- 4th Case: One Way Construction Ltd**
- Date case filed: 16 March 2026
- Count I: Causing a scaffold, except an excluded scaffold, to be constructed, erected, installed, re-positioned, altered, maintained, repaired or dismantled without holding a Scaffold Contractor's Permit or enlisting the services of a scaffold contractor. Was sentenced to a fine of Rs2,000/- and cost of Rs200/-.
- 5th Case: Lilmo Ltd**
- Date case filed: 04 December 2025
- Count I: Failing to prevent danger by earthing. Was sentenced to a fine of Rs5,000/- and cost of Rs200/-.
- 6th Case: Lilmo Ltd**
- Date case filed: 04 December 2025
- Count I: Failing to provide suitable means, including methods of identifying circuits, so as to cut-off the supply of electrical energy to any electrical equipment. Was sentenced to a fine of Rs5,000/-.
- Count II: Failing to ensure the safety of his employees from risks of electric shock by taking appropriate protective measures. Was sentenced to a fine of Rs5,000/-.

- Count III: Failing to ensure that the electrical system was not so constructed as to prevent danger at all times. Was sentenced to a fine of Rs5,000/- and cost of Rs200/- for the three counts.
- 7th Case: Velogic Haulage Services Ltd**
- Date case filed: 28 January 2026
- Count I: Failing to forthwith notify the Director, National Occupational Safety and Health Department of an accident arising out of or in connection with work by the quickest practicable means. Was sentenced to a fine of Rs3,000/- and cost of Rs200/-
- 8th Case: Lab Fifty One Limited**
- Date case filed: 26 April 2023
- Count I: Failing to ensure, so far as is reasonably practicable, the safety, health and welfare at work of its employees. Case dismissed.
- 9th Case: Johnson Construction Renovation Ltd**
- Date case filed: 29 September 2025
- Count I: Failing to ensure that every scaffold including each member or component thereof is of good construction.
- Count II: Failing to ensure that the scaffold is effectively braced by means of longitudinal and transverse bracing systems which extend from the base to the top of the scaffold.
- Count III: Failing to ensure that every side of a work platform from which a person is liable to fall more than 2 meters is provided with toe-boards and 2 or more guardrails. Case dismissed.
- 10th Case: National Transport Corporation**
- Date case filed: 30 March 2026
- Count I: Failing to install residual current devices having a rated residual operating current of 30 milliamperes. Was sentenced to a fine of Rs2,000/-.
- Count II: Failing to install residual current devices having a rated residual operating current of 30 milliamperes. Was sentenced to a fine of Rs2,000/- and cost of Rs200/- for both counts.
- 11th Case: Le Tricot International Limited**
- Date case filed: 30 March 2026
- Count I: Failing to ensure the safety of employees from risks of electric shock by taking appropriate protective measures. Was sentenced to a fine of Rs1,500/-.
- Count II: Failing to ensure the safety of employees from risks of electric shock by taking appropriate protective measures. Was sentenced to a fine of Rs1,500/-.

Count III: Failing to ensure the safety of employees from risks of electric shock by taking appropriate protective measures. Was sentenced to a fine of Rs1,500/- and cost of Rs200/- for the three counts.

12th Case: Le Tricot International Limited

Date case filed: 30 March 2026

Count I: Failing to provide suitable means, including methods of identifying circuits, so as to cut-off the supply of electrical energy to any electrical equipment. Was sentenced to a fine of Rs1,500/-.

Count II: Failing to provide suitable means, including methods of identifying circuits, so as to cut-off the supply of electrical energy to any electrical equipment. Was sentenced to a fine of Rs1,500/-.

Count III: Failing to ensure the safety of employees from risks of electric shock by taking appropriate protective measures. Was sentenced to a fine of Rs1,500/- and cost of Rs200/- for the three counts.